

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report

Division Name: P.H. Division, Ara

Date of Sampling :- 05-07-2025
Date of Testing :- 07-07-2025

District Name : Bhojpur
Sample Collected By : Self

Sample Collected By : Self						Parameters															Remarks
S	Block	Panchayat	Village	Location of Source	Ward No.	pH	Turb-	EC	TDS	TH	Ca	Mg	Cl	Alka	Fe ⁺⁺	NO ₃	SO ₄	F	As	Total Coll	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
1	Koilwer	-	Mathurapur	Boring Water Of Royal Public School Mathurapur :Koilwer (Bhojpur) Bihar	-	7.313	3.7	289	187	180	35.27	22.35	49.97	200	0.28	NT	NT	NT	BDL	-ve	Safe
						6.5-8.5	1	-	500	200	75	30	250	200	1	45	200	1	0.01	-	
Permissible Limit in absence of alternative source						NR	5	-	2000	600	200	100	1000	500	NR	NR	400	1.5	NR	-	

*NT = Not Tested, BDL=Below Detection Limit

[Signature]
Research Assistant
(Chemist)
P.H. Division, Ara